

**TO WHOM IT MAY CONCERN**

That the premises of **Seventh-Day Adventist Mission High School Housing Board Colony Stadium Road, Rohru** was inspected on **13-02-2015** with reference to their application no. **Nil** dated **28-12-2014** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported /recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two year (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
Seventh-Day Adventist Mission High School  
Housing Board Colony Stadium Road, Rohru, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Ashok Kumar, Khullar Bazar, Summerhill Shimla** were inspected on **30-01-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager,  
Ashok Kumar Khullar Bazar, Summerhill,  
Shimla, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Shikhar Wool Processors, Village Brow, P.O. Rampur Bushahr, Tehsil Nirmand** were inspected on **12-02-2015** with reference to their application no. **L&E(FAC)9-20143038-1509** dated **04-02-2015** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager,  
Shikhar Wool Processors, Village Brow,  
P.O. Rampur Bushahr, Tehsil Nirmand, Distt. Kullu H.P**

**TO WHOM IT MAY CONCERN**

That the premises of **Jarnail Brothers, Welding Works, B.C.S. New Shimla** were inspected on **1-03-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 16-03-2015 to 15-03-2017) subject to fulfillment of following condition:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor  
Jarnail Brothers,  
Welding Works B.C.S New Shimla,  
Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **S.D. Public School Nerwa, Tehsil Chopal** was inspected on **24-03-2015** with reference to their application no. **Nil** dated **28-12-2014** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported /recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found in working order at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for one year (i.e. 25-03-2015 to 24-03-2016) subject to fulfillment of the following conditions:-

1. It is recommended to install 01No. CO2 Fire Extinguisher of 4.5kg capacity and 01 No. Water Type Fire Extinguisher of 9 litre capacity in the school premises.
2. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
3. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
4. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
S.D. Public School Nerwa,  
Tehsil Chopal, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Living Values Public School Chopal, Tehsil Chopal** was inspected on **24-03-2015** with reference to their application no. **Lvps/affi/238** dated **29-12-2014** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported /recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found in working order at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for one year (i.e. 25-03-2015 to 24-03-2016) subject to fulfillment of the following conditions:-

1. It is recommended to install 01No. CO2 Fire Extinguisher of 4.5kg capacity in the school premises.
2. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
3. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
4. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
Living Value Public School Chopal,  
Tehsil Chopal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Jarnail Brothers, Welding Works, B.C.S. New Shimla** were inspected on **1-03-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 16-03-2015 to 15-03-2017) subject to fulfillment of following condition:-

4. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
5. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
6. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor  
Jarnail Brothers,  
Welding Works B.C.S New Shimla,  
Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Seventh-Day Adventist Mission High School Housing Board Colony Stadium Road, Rohru** was inspected on **13-02-2015** with reference to their application no. **Nil** dated **28-12-2014** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported /recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two year (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

4. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
5. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
6. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
Seventh-Day Adventist Mission High School  
Housing Board Colony Stadium Road, Rohru, Distt. Shimla H.P.**



**TO WHOM IT MAY CONCERN**

That the premises of **Ashok Kumar, Khullar Bazar, Summerhill Shimla** were inspected on **30-01-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

4. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
5. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
6. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager,  
Ashok Kumar Khullar Bazar, Summerhill,  
Shimla, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Shikhar Wool Processors, Village Brow, P.O. Rampur Bushahr, Tehsil Nirmand** were inspected on **12-02-2015** with reference to their application no. **L&E(FAC)9-20143038-1509** dated **04-02-2015** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 04-03-2015 to 03-03-2017) subject to fulfillment of the following conditions:-

4. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
5. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
6. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager,  
Shikhar Wool Processors, Village Brow,  
P.O. Rampur Bushahr, Tehsil Nirmand, Distt. Kullu H.P**

**TO WHOM IT MAY CONCERN**

That the premises of **Jarnail Brothers, Welding Works, B.C.S. New Shimla** were inspected on **1-03-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 16-03-2015 to 15-03-2017) subject to fulfillment of the following conditions:-

7. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
8. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
9. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor  
Jarnail Brothers,  
Welding Works B.C.S New Shimla,  
Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-2333 dated 21-03-2016 Shimla-2**  
**TO WHOM IT MAY CONCERN**

That the premises of **Princeton School Phase-III, Sector-V, B.C.S. New Shimla-9** was inspected on **9-04-2015** with reference to their application no. **321** dated **12-03-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found in working order at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for one year (i.e.9-04-2015 to 8-04-2016) subject to fulfillment of the following conditions:-

1. It is recommended that work regarding installation of Hose Reel Hose in the school premises should be completed as early as possible.
2. 04 Nos. CO2 Fire Extinguishers of 4.5 kg capacity and 04 Nos. Water Type Fire Extinguishers of 9 litre capacity in pairs should also be installed in every floor of the school building.
3. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
4. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
5. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
Princeton School Phase-III, Sector-V,  
B.C.S. New Shimla-9, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Shiva Tea Stall, Mohan Niwas, Kasumpati** were inspected on **20-03-2015** with reference to their application no. **Nil** dated **17-01-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 8-04-2015 to 7-04-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
Sh. Tilak Raj Chadda  
Shiva Tea Stall Mohan Niwas Kasumpati,  
Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Punam Rohal Enterprises, Village Ganeri (Kayllu), P.O. Soghi, Tehsil & Distt. Shimla** were inspected on **20-03-2015** with reference to their application no. **Nil** dated **19-03-2015** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 22-04-2015 to 21-04-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor  
Punam Rohal Enterprises, Village Ganeri (Kayllu),  
P.O. Soghi, Tehsil & Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Tata Tele Services Limited Kasumpati** were inspected on **17-03-2015** with reference to their application no. **Nil** dated **20-01-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 27-04-2015 to 26-04-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager  
Tata Tele Services Limited Kasumpati, Shimla  
Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Kamla Thakur, (Tea Shop), Near Prabhu Dass Clinic, Airport Road, Lower Totu Shimla** were inspected on **21-03-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.29-04-2015 to 28-04-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.

emarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
Smt. Kamla Thakur, (Tea Shop),  
Near Prabhu Dass Clinic,  
Airport Road, Lower Totu Shimla, Distt. Shimla H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-4738 dated 10-08-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Vineet Gas Agency Longwood, Shimla** were inspected on **10-07-2015** with reference to their application no. **Nil** dated **8-07-2015** by the **Incharge, Fire Station, The Mall Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.10-08-2015 to 9-08-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. You are advised to comply with the storage rule laid down by the Chief Controller of explosive with latest amendment, failing which this certificate shall be treated as cancelled.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor,  
Vineet Gas Agency Longwood,  
Shimla-171001**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC- dated Shimla-2**  
**TO WHOM IT MAY CONCERN**

That the premises of **Princeton School Phase-III, Sector-V, B.C.S. New Shimla-9** was inspected on **9-04-2015** with reference to their application no. **321** dated **12-03-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found in working order at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for one year (i.e.9-04-2015 to 8-04-2016) subject to fulfillment of the following conditions:-

1. It is recommended that work regarding installation of Hose Reel Hose in the school premises should be completed as early as possible.
2. 04 Nos. CO2 Fire Extinguishers of 4.5 kg capacity and 04 Nos. Water Type Fire Extinguishers of 9 litre capacity in pairs should also be installed in every floor of the school building.
3. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
4. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
5. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Principal,  
Princeton School Phase-III, Sector-V,  
B.C.S. New Shimla-9, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**  
**TO WHOM IT MAY CONCERN**

That the premises of **St. Bede's College (JBT Block), Shimla-2** were inspected on **14-08-2015** with reference to their application no. **Nil** dated **4-08-2015** by the **Sub Fire Officer, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.18-08-2015 to 17-08-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,  
**The Principal,**  
**St. Bede's College (JBT Block),**  
**Shimla-171002**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Kamla Thakur, (Tea Shop), Near Prabhu Dass Clinic, Airport Road, Lower Totu Shimla** were inspected on **21-03-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.29-04-2015 to 28-04-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.

emarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
Smt. Kamla Thakur, (Tea Shop),  
Near Prabhu Dass Clinic,  
Airport Road, Lower Totu Shimla, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC- 5456 dated 25-08-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Wild Flower Hall, Mashobra Resorts Ltd. Chharabra, Shimla,** were inspected on **30-07-2015** with reference to their application no **Nil** dated **28-04-2015** by the **Incharge, Fire Station, Chhota Shimla,** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.22-08-2015 to 21-08-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Chief Engineer**  
**Wild Flower Hall, Mashobra Resorts Ltd. Chharabra,**  
**Shimla, Distt. Shimla, H.P. 171012**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-5483 dated 27-08-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Tibetan Dhaba, Stall No. 9, Subzi Mandi, Shimla-1** were inspected on **4-07-2015** with reference to their application no **Nil** dated **28-04-2015** by the **Incharge, Fire Station, Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.22-08-2015 to 21-08-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**Sh. Lakshay**  
**Tibetan Dhaba, Stall No. 9,**  
**Subzi Mandi, Shimla-171001**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6240 dated 22-09-2015 Shimla-2**  
**TO WHOM IT MAY CONCERN**

That the premises of **Ramesh Chauhan So-Sherill Villa Panthagatti Shimla-9** were inspected on **16-09-2015** with reference to their application no. **Nil** dated **28-06-2015** by the **Incharge, Fire Station Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two Years (i.e.21-09-2015 to 20-09-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,  
**Ramesh Chauhan,**  
**So-Sherill Villa Panthagatti Shimla-9**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir High School Vikasnagar, Shimla-1** were inspected on **4-07-2015** with reference to their application no **Nil** dated **28-04-2015** by the **Incharge, Fire Station, Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.22-08-2015 to 21-08-2017) subject to fulfillment of the following conditions:-

4. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
5. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
6. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**Sh. Lakshay**  
**Tibetan Dhaba, Stall No. 9,**  
**Subzi Mandi, Shimla-171001**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6415 dated 30-09-2015 Shimla-2**  
**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir, High School Vikas nagar, Shimla-9** were inspected on **20-08-2015** with reference to their application no. **Nil** dated **01-06-2015** by the **Sub Fire Officer, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-09-2015 to 28-09-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer**  
**Himachal Pradesh Shimla-2**

**To,**  
**The Principal,**  
**Saraswati Vidya Mandir,**  
**High School Vikas nagar, Shimla-171009**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6416 dated 30-09-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir Him Rashmi parisar, Vikasnagar, Shimla-9** were inspected on **17-08-2015** with reference to their application no. **Nil** dated **14-05-2015** by the **Sub Fire Officer, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-09-2015 to 28-09-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

**To,**

**The Principal,**  
**Saraswati Vidya Mandir,**  
**Him Rashmi parisar, Vikasnagar, Shimla-171009**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6417 dated 30-09-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **St. Josoph's High School Rohru Distt. Shimla-H.P.** were inspected on **24-05-2015** with reference to their application no. **Nil** dated **17-04-2015** by the **Sub Fire Officer, Fire Station, Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-09-2015 to 28-09-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**St. Josoph's High School,**  
**Rohru Distt. Shimla-H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7609 dated 23-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Aryan Public School Kansakoti, Tehsil Rohru Distt. Rohru H.P.** were inspected on **24-04-2015** with reference to their application no. **Nil** dated **17-03-2015** by the **Sub Fire Officer, Fire Station, Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-09-2015 to 28-09-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Aryan Public School Kansakoti,**  
**Tehsil Rohru Distt. Rohru H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6413 dated 30-09-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Kids Choice Public School, Hari Aashram Chakkar, Shimla-5** were inspected on **21-08-2015** with reference to their application no. **Nil** dated **17-03-2015** by the **Incharge, Fire Station, Tilak Nagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-09-2015 to 28-09-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Kids Choice Public School,  
Hari Aashram Chakkar, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6508 dated 07-10-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Balvinder Singh , Scrap Works, Thakur Niwas, Shanan, Sanjauli** were inspected on **22-07-2015** with reference to their application no **Nil** dated **Nil** by the **Incharge, Fire Station, Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.5-10-2015 to 4-10-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**Sh. Balvinder Singh , Scrap Works,  
Thakur Niwas, Village Shanan, Sanjauli,  
Tehsil Shimla (R), Distt. Shimla H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6788 dated 17-10-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Mata Bhakti Devi Welfare Society (regd.) Indian Institute of Educational & Legal Studies, Hari Devi, Ghanahatti Distt. Shimla H.P.** were inspected on **12-10-2015** with reference to their application no. **Nil** dated **03-10-2015** by the **Incharge, Fire Station, Tilak Nagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.17-10-2015 to 16-10-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Principal,  
Mata Bhakti Devi Welfare Society (regd.)**



**Indian Institute of Educational & Legal Studies,**  
**Hari Devi, Ghanahatti Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6787 dated 17-10-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Raghav Public School Ghaini, V.P.O. Ghaini, Tehsil Suni, Distt. Shimla H.P.** were inspected on **06-10-2015** with reference to their application no. **RPS/011** dated **03-10-2015** by the **Incharge, State Fire Training Center, Baldeyan.** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.17-10-2015 to 16-10-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

**To,**  
**The Principal,**

**Raghav Public School Ghaini,**  
**V.P.O. Ghaini, Tehsil Suni, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6804 dated 19-10-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Hill Top Public School Narkanda, Distt. Shimla H.P. were inspected on 17-10-2015 with reference to their application no. Nil dated 09-10-2015 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-10-2015 to 19-10-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,  
**The Principal,**  
**Hill Top Public School Narkanda,**  
**Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Mahant Floor Mill Village Sariya, P.O. Baldeyan, Distt. Shimla H.P.** were inspected on **15-10-2015** with reference to their application no **Nil** dated **28-07-2015** by the **Incharge, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.23-10-2015 to 22-10-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor  
Mahant Flour Mill, Village Sariya,  
P.O. Baldeyan, Distt. Shimla H.P**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-6996 dated 31-10-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **City Public School Kamla Nagar Battakuffri, Distt. Shimla H.P.** were inspected on **30-10-2015** with reference to their application no. **Nil** dated **03-10-2015** by the **Incharge, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.31-10-2015 to 30-10-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,  
**The Principal,**  
**City Public School Kamla Nagar Battakuffri,**  
**Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Prem Public School Theog, Distt. Shimla, H.P.** were inspected on **20-10-2015** with reference to their application no. **PPS(misc) 2015-859** dated **12-10-2015** by the **Incharge, Fire Post, Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.02-11-2015 to 01-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Prem Public School Theog,  
Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7004 dated 02-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Competition Zone Education Society Theog**, were inspected on **21-10-2015** with reference to their application no. **Nil** dated **09-09-2015** by the **Incharge, Fire Post, Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.02-11-2015 to 01-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Competition Zone Education Society Theog,**  
**Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Sarvahitkari Public High School Gadli (Gadakufri), P.O Bharana, Tehsil Theog, Distt. Shimla** were inspected on **21-10-2015** with reference to their application no. **EDN-SPS-G(GK) 25/2015** dated **01-09-2015** by the **Incharge, Fire Post, Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.02-11-2015 to 01-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Sarvahitkari Public High School Gadli (Gadakufri),  
P.O Bharana, Tehsil Theog, Distt. Shimla, H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**

**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Hotel Blossom, Amar Tara Estate, Near R.T.O. Office Shimla,** were inspected **15-03-2012** with reference to their application no. **Nil** dated **Nil** by the SFO, Fire Station The Mall Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found in working order at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for one year (i.e.21-03-2012 to 20-03-2013) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
1. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Managing Director,  
Hotel Blossom, Amar Tara Estate ,  
Near R.T.O.Office Shimla Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Hotel Blossom, Near RTO Office Shimla-171004** were inspected on **2-09-2015** with reference to their application no **Nil** dated **Nil** by the **Incharge, Fire Station, Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.3-11-2015 to 2-11-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor  
Hotel Blossom,  
Near RTO Office Shimla-171004,**

**TO WHOM IT MAY CONCERN**

That the premises of **R.S. Puran Mall Dharamshala Trust, Main Bus Stand, Shimla-1** were inspected on **08-09-2015** with reference to their application no **RSPMD/MISC.2015-16** dated **31-08-2015** by the **Incharge, Fire Station, The Mall Road** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.3-11-2015 to 2-11-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Proprietor**  
**R.S. Puran Mall Dharamshala Trust,**  
**Main Bus Stand, Shimla-1**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7421 dated 12-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Shirgul Public School Ghund, Tehsil Theog, Distt. Shimla** were inspected on **12-10-2015** with reference to their application no. **Nil** dated **07-10-2015** by the **Incharge, Fire Post, Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.12-11-2015 to 11-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Shirgul Public School Ghund,  
Tehsil Theog, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7553 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Kamla Memorial Sr.Sec.School Rampur, P.O. & Tehsil Rampur** were inspected on **15-09-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Kamla Memorial Sr.Sec.School Rampur,**  
**P.O. & Tehsil Rampur, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7554 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Kamla Memorial Public School Jakhari, P.O. Jakhari, Tehsil Rampur** were inspected on **15-09-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Kamla Memorial Public School Jakhari,  
P.O. Jakhari, Tehsil Rampur, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **St. Merry School Nankhari, VPO & Sub Tehsil Nankhari, Tehsil Rampur** were inspected on **16-09-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**St. Merry School Nankhari,**  
**P.O. & Sub Tehsil Nankhari,**  
**Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7556 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **City Life Public School Dhanda, Shimla-11** were inspected on **20-10-2015** with reference to their application no. **CLPS/2015.16/17** dated **15.10.2015** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**City Life Public School Dhanda, Shimla,**  
**Tehsil Shimla, Distt. Shimla, H.P. -171011**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7552 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Rising High Public School Jathia Devi, Tehsil Shimla, Distt. Shimla** were inspected on **27-10-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Rising High Public School Jathia Devi,  
Tehsil Shimla, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7557 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Gyan Jyoti Public School Theog** were inspected on **27-10-2015** with reference to their application no. **Nil** dated **29-09-2015** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Gyan Jyoti Public School Theog,**  
**Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7558 dated 21-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Jagdamba Public School Jabbal (Dawaroo), P.O. Chanawag, Tehsil Suni** were inspected on **3-11-2015** with reference to their application no. **Nil** dated **08-2014** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-11-2015 to 19-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Jagdamba Public School Jabbal (Dawaroo),  
P.O. Chanawag, Tehsil Suni, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7680 dated 26-11-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Sacred Heart Convent, Block-2, Fleur-de-Lys, Dhalli, Shimla were inspected on 23-11-2015 with reference to their application no. Nil dated 21.11.2015 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.24-11-2015 to 23-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Sacred Heart Convent, Block-2,**  
**Fleur-de-Lys, Dhalli, Tehsil & Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7895 dated 04-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Modern Public School Fagu, Tehsil Theog** were inspected on **21-11-2015** with reference to their application no. **Nil** dated **18-11-2015** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.01-12-2015 to 30-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein. seek
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Principal,  
Modern Public School Fagu,  
Tehsil Theog, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7894 dated 04-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Santosh Public High School Sainj, Tehsil Theog** were inspected on **24-11-2015** with reference to their application no. **Nil** dated **04-11-2015** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.01-12-2015 to 30-11-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Santosh Public High School Sainj,  
Tehsil Theog, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-7879 dated 03-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Sigma School of Science Village Dakolar, P.O. Singla, Tehsil Rampur, Distt. Shimla** were inspected on **29-11-2015** with reference to their application no. **Nil** dated **25-11-2015** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.02-12-2015 to 01-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Sigma School of Science Village Dakolar,  
P.O. Singla, Tehsil Rampur, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Sigma School of Science Village Dakolar, P.O. Singla, Tehsil Rampur, Distt. Shimla** were inspected on **29-11-2015** with reference to their application no. **Nil** dated **25-11-2015** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.02-12-2015 to 01-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Sigma School of Science Village Dakolar,  
P.O. Singla, Tehsil Rampur, Distt. Shimla, H.P.**



**TO WHOM IT MAY CONCERN**

That the premises of **Hotal Mari Gold Holidays Cottage, Village Sadhora, Naldehra Road, P.O. Baldeyan, Distt. Shimla** were inspected on **28-10-2015** with reference to their application no **Nil** dated **Nil** by the **Incharge, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.09-12-2015 to 08-12-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Proprietor  
Hotal Mari Gold Holidays Cottage,  
Village Sadhora, Naldehra Road,  
P.O. Baldeyan, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC- 8119 dated 10-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Hill Crest Country Resort Sadhora (Mashobra)** **Distt. Shimla** were inspected on **28-10-2015** with reference to their application no **232/2015-16/42** dated **24-08-2015** by the **Incharge, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.09-12-2015 to 08-12-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

**To,**

**The Proprietor**  
**Hill Crest Country Resort Sadhora (Mashobra)**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8120 dated 10-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Hotal Mari Gold Holiday Cottage, Village Sadhora, Naldehra Road P.O. Baldeyan Shimla** were inspected on **28-10-2015** with reference to their application no **Nil** dated **Nil** by the **Incharge, Fire Station, Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.07-12-2015 to 06-12-2017) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained within the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor**  
**Hotal Mari Gold Holiday Cottage,**  
**Village Sadhora, Naldehra Road,**  
**P.O. Baldeyan Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8195 dated 16-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Bhuvneshwary Public School V.P.O. Arsu, Tehsil Nirmand** were inspected on **21-11-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.16-12-2015 to 15-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Bhuvneshwary Public School V.P.O. Arsu,  
Tehsil Nirmand, Distt. Kullu, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8346 dated 23-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of Crescent Sr. Sec.School Totu, Shimla were inspected on 24-11-2015 with reference to their application no. Nil dated 14-12-2015 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Crescent Sr. Sec.School Totu, Shimla,  
Distt. Kullu, H.P

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8362 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Shri Khand Mahadev Public School Rajori, P.O. Arsu, Tehsil Nirmand** were inspected on **21-11-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shri Khand Mahadev Public School Rajori,**  
**P.O. Arsu, Tehsil Nirmand, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8361 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Saraswati Vidya Mandir Village Kungasgh, P.O. Poeg, Tehsil Anni** were inspected on **7-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir Village Kungash,**  
**P.O. Poeg, Tehsil Anni, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Bhuvneshwari Public School V.P.O. Arsu, Tehsil Nirmand** were inspected on **21-11-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Bhuvneshwari Public School V.P.O. Arsu,**  
**Tehsil Nirmand, Distt. Kullu H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8363 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Astha Public School VPO Tandi, Sub Tehsil Nither, Kullu** were inspected on **8-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Astha Public School VPO Tandi,**  
**Sub-Tehsil Nither, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8360 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Lawrence Public School Chowai, P.O. Chowai, Tehsil Anni** were inspected on **8-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Lawrence Public School Chowai, P.O. Chowai,**  
**Tehsil Anni, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8359 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Sunshine Public School Raibag, P.O. Khun, Tehsil Anni** were inspected on **8-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Sunshine Public School Raibag, P.O. Khun,**  
**Tehsil Anni, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8364 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Shiv Shakti Public School VPO Nirath, Tehsil Rampur** were inspected on **9-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shiv Shakti Public School V.P.O. Nirath,**  
**Tehsil Rampur, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8365 dated 29-12-2015**

**Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir VPO Baragaon, Tehsil Kumarsain were inspected on 11-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Saraswati Vidya Mandir VPO Baragaon,  
Tehsil Kumarsain, Distt. Shimla H.P.

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8366 dated 29-12-20165 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Shivalik Public School VPO Jhakri, Tehsil Rampur** were inspected on **12-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shivalik Public School VPO Jhakri,**  
**Tehsil Rampur, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8367 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of Green Valley Public School Shiwan P.O. Shiwan, Tehsil Kumarsain were inspected on 30-10-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Green Valley Public School Shiwan P.O. Shiwan,  
Tehsil Kumarsain, Distt. Shimla H.P.

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8368 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of **Little Flower Public School Village Baroh, Tehsil Nirmand** were inspected on **1-12-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Little Flower Public School Village Baroh,**  
**Tehsil Nirmand, Distt. Kullu H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8358 dated 29-12-2015 Shimla-2**

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir High School Nirmand, Distt. Kullu were inspected on 21-11-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Saraswati Vidya Mandir High School Nirmand,  
Distt. Kullu H.

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8337 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Chambu Public High School Urtoo, Tehsil Nirmand, Distt. Kullu** were inspected on **28-11-2015** with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Chambu Public High School Urtoo,**  
**Tehsil Nirmand, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8369 dated 29-12-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Model Public School Pharbog, P.O. Shawad, Tehsil Anni** were inspected on **07-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-12-2015 to 22-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Model Public School Pharbog,**  
**P.O. Shawad, Tehsil Anni, Distt. Kullu H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Himadri Public High School New Nerwa, Tehsil Chopal,** were inspected on **16-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Headmaster,**  
**Himadri Public High School New Nerwa,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8417 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Vinayak Public School Samoli, Tehsil Rohru**, were inspected on **20-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Headmaster,**  
**Vinayak Public School Samoli,**  
**Tehsil Rohru, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8418 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Key Dee Public School Jubbal, Tehsil Jubbal**, were inspected on **14-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Key Dee Public School Jubbal,**  
**Tehsil Jubbal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8415 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidhya Mandir Nerwa, Tehsil Chopal,** were inspected on **16-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidhya Mandir Nerwa,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidhya Mandir Jubbal, Tehsil Jubbal,** were inspected on **14-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidhya Mandir Jubbal,**  
**Tehsil Jubbal, Distt. Shimla H.P.**



**TO WHOM IT MAY CONCERN**

That the premises of **Anand Marg High School Chopal, Tehsil Chopal**, were inspected on **14-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Anand Marg High School Chopal,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**

**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Anand Marg High School Chopal, Tehsil Chopal**, were inspected on **14-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Anand Marg High School Chopal,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8421 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Nerwa Public High School, V.P.O Nerwa, Tehsil Chopal,** were inspected on **05-12-2015** with reference to their application no. **Nil** dated **04-07-2015** by the **Incharge, Fire Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Nerwa Public High School, V.P.O Nerwa,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8374 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Gayatri Public School Jangla, Tehsil Chirgaon,** were inspected on **24-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Gayatri Public School Jangla,**  
**Tehsil Chirgaon, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8372 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Maya Public Sr. Sec. School Sunni**, were inspected on **30-11-2015** with reference to their application no. **Nil** dated **Nil** by the **L.F.M, Fire Training Centre Baldeyan** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Maya Public Sr. Sec. School Sunni,**  
**Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Maya Public High School Mashobra, Tehsil & Distt. Shimla** were inspected on **14-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Maya Public High School Mashobra,**  
**Tehsil & Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **S.P.M Model High School Sanjauli, Distt. Shimla** were inspected on **20-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**S.P.M Model High School Sanjauli,**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8376 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Dev International School Maraog, P.O Maraog, Tehsil Chopal,** were inspected on **15-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Dev International School Maraog, P.O Maraog,**  
**Tehsil Chopal, Distt. Shimla H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8377 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Ishan Sr. Sec. Public School Theog,** were inspected on **08-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.28-12-2015 to 27-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Ishan Sr. Sec. Public School Theog,**  
**Distt. Shimla H.P**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8381 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Gumma Public Sr.Sec.School Gumma** were inspected on **26-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Training Centre Baldeyan** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-12-2015 to 28-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Gumma Public Sr.Sec.School Gumma,**  
**Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Aastha Public School Banooti, Shimla-11** were inspected on **22-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-12-2015 to 28-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Aastha Public School Banooti,**  
**Shimla-11, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8404 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Ambika Public School V.P.O. & Tehsil Nirmand, Distt. Kullu** were inspected on **21-11-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-12-2015 to 28-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Ambika Public School**  
**V.P.O. & Tehsil Nirmand, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8407 dated 29-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Lord Parshuram Public School Nirmand, VPO & Tehsil Nirmand** were inspected on **28-11-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.29-12-2015 to 28-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Lord Parshuram Public School Nirmand,**  
**VPO & Tehsil Nirmand, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir V.P.O. Anni, Distt. Kullu** were inspected on **7-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir V.P.O. Anni,**  
**Tehsil Anni, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir V.P.O. Anni, Distt. Kullu** were inspected on **7-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir V.P.O. Anni,**  
**Tehsil Anni, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Shivalik Public School Dobi, P.O. Kartot, Tehsil Rampur** were inspected on **9-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shivalik Public School Dobi,**  
**P.O. Kartot, Tehsil Rampur, Distt. Kullu H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8438 dated 30-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Shishu Shiksha Niketan High School Totu, Shimla** were inspected on **24-12-2015** with reference to their application no. **Nil** dated **24-12-2015** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shishu Shiksha Niketan High School Totu,**  
**Shimla, Distt. Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8439 dated 30-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir Halog, Dhami** were inspected on **24-11-2015** with reference to their application no. **SVM/21A/15** dated **7-10-2015** by the **Incharge, Fire Station Tilaknagar** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir Halog, Dhami,**  
**Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir High School Kotkhai, Distt. Shimla** were inspected on **29-10-2015** with reference to their application no. **20/15** dated **20-09-2015** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir High School Kotkhai,**  
**Tehsil Kotkhai, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8500 dated 31-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Rashtriya Vidya Kendre Public School VPO Duttnagar, Tehsil Rampur** were inspected on **17-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Rashtriya Vidya Kendre Public School VPO Duttnagar,**  
**Tehsil Rampur, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8502 dated 31-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Sanskar Public School Dakolar, Village Dakolar (New Rampur), P.O. & Tehsil Rampur** were inspected on **5-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Sanskar Public School Dakolar(New Rampur),**  
**P.O. & Tehsil Rampur, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8501 dated 31-12-2015 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Sai Vidya Public School Padamnagar P.O. & Tehsil Rampur Bushahar** were inspected on **5-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.30-12-2015 to 29-12-2017) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Sai Vidya Public School Padamnagar**  
**P.O. & Tehsil Rampur Bushahar, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-48 dated 06-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Bharat Public School Chopal, Tehsil Chopal were inspected on 4-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.6-01-2016 to 5-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Bharat Public School Chopal,**  
**Tehsil Chopal, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **Glory International Public High School Bharara Road, Rohru, Distt Shimla** were inspected on **24-11-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.06-01-2016 to 05-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Glory International Public High School Bharara Road,**  
**Rohru, Distt Shimla H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Shivalik Public School Chirgaon, Tehsil Chirgaon, Distt Shimla** were inspected on **30-11-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.06-01-2016 to 05-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Shivalik Public School Chirgaon,**  
**Tehsil Chirgaon, Distt Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **S.D Public High School Nerwa, Tehsil Chopal, Distt Shimla** were inspected on **16-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.06-01-2016 to 05-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**S.D Public High School Nerwa,**  
**Tehsil Chopal, Distt Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-96 dated 07-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **J.C.B Public School Khalini, Shimla-9,** were inspected on **31-12-2015** with reference to their application no. **JCB/CFO/NOC/2015** dated **16-12-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.06-01-2016 to 05-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**J.C.B Public School Khalini,**  
**Shimla-9, Distt Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-379 dated 18-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Hotel Gulmarg Near, The Mall Shimla** were inspected on **22-12-2015** with reference to their application no **GH/08/2015** dated **11-09-2015** by the **Divisional Fire Officer, Fire Division Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.12-01-2016 to 11-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Manager**  
**Hotel Gulmarg Near, The Mall Shimla ,**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-380 dated 18-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **New Gulmarg Hotel Near The Mall Shimla** were inspected on **22-12-2015** with reference to their application no **NGH/08/2015** dated **11-09-2015** by the **Divisional Fire Officer, Fire Division Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.12-01-2016 to 11-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Manager**  
**New Gulmarg Hotel Near The Mall Shimla,**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-378 dated 18-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Hotal Gulmarg Regency Near The Mall Shimla,** were inspected on **22-12-2015** with reference to their application no **HGR/08/2015** dated **11-09-2015** by the **Divisional Fire Officer, Fire Division Shimla,** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.12-01-2016 to 11-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Manager**  
**Hotal Gulmarg Regency Near The Mall Shimla,**  
**Distt. Shimla H.P.**



**TO WHOM IT MAY CONCERN**

That the premises of **Bharat Public School Chopal, Tehsil Chopal,** were inspected on **04-12-2015** with reference to their application no. **Nil** dated **26-10-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.12-01-2016 to 11-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Bharat Public School Chopal,**  
**Tehsil Chopal, Distt Shimla H.P.**



**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-309 dated 12-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Aradhana Public School Rohru** were inspected on **18-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.12-01-2016 to 11-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Aradhana Public School Rohru,**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-439 dated 19-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Bhagwati Vidya Mandir Public School Kupvi, Distt. Shimla** were inspected on **17-01-2016** with reference to their application no. **Nil** dated **4-12-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.19-01-2016 to 18-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Bhagwati Vidya Mandir Public School Kupvi,**  
**Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-473 dated 20-12-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Panorma Television Pvt. Ltd. (ETV Haryana), Marlborough House, Chhota Shimla** were inspected on **11-12-2015** with reference to their application no **Nil** dated **31-08-2015** by the **Sub Fire Officer, Fire Station Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Proprietor**  
**Panorma Television Pvt. Ltd. (ETV Haryana),**  
**Marlborough House, Chhota Shimla, Distt. Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Him Spring Dale School V.P.O. Khaneri, Tehsil Rampur** were inspected on **15-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Him Spring Dale School V.P.O. Khaneri,**  
**Tehsil Rampur, Distt Shimla H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-674 dated 23-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Himalayan Model Sr.Sec.School V.P.O. & Tehsil Anni** were inspected on **24-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Himalayan Model Sr.Sec.School**  
**VPO & Tehsil Anni, Distt Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-                      dated                      Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Aryavert Public School Dalash, Tehsil Anni** were inspected on **24-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rampur** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Aryavert Public School Dalash,**  
**Tehsil Anni, Distt Kullu H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-543 dated 21-01-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of **Saraswati Vidya Mandir High School Gyan Deep Parisar, Kamla Nagar Dhalli, Shimla** were inspected on **12-01-2016** with reference to their application no. **B-2015-16** dated **23-12-2015** by the **Incharge, Fire Station Chhota Shimla** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Saraswati Vidya Mandir High School Gyan Deep Parisar,**  
**Kamla Nagar Dhalli, Shimla- 171006.**

**TO WHOM IT MAY CONCERN**

That the premises of **Ras Resort Pvt. Ltd. Village Galu Near Kufri, NH-22, Shimla** were inspected on **8-01-2016** with reference to their application no **Nil** dated **Nil** by the **Sub Fire Officer, Fire Station Chhota Shimla**, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor**  
**Ras Resort Pvt. Ltd. Village Galu Near Kufri,**  
**NH-22, Shimla, Distt. Shimla H.P**



**TO WHOM IT MAY CONCERN**

That the premises of **Maheshwari Public School Cheog, Tehsil Theog** were inspected on **30-12-2015** with reference to their application no. **M.P.S.F-14/59-2015-16** dated **10-12-2015** by the **Incharge, Fire Post Theog** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-01-2016 to 19-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

**The Principal,**  
**Maheshwari Public School Cheog,**  
**Tehsil Theog, Distt. Shimla.**

**TO WHOM IT MAY CONCERN**

That the premises of Sharma Stone Crusher, Village Slava, P.O. Soghi, Tehsil & Distt. Shimla were inspected on 30-11-2015 with reference to their application no Nil dated usher, Nil by the Incharge, Fire Station Tilaknagar, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.28-01-2016 to 27-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor**  
**Sharma Stone Crusher, Village Slava, P.O. Soghi,**  
**Tehsil & Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of Laxmi Stone Crusher, Village Lachog, Tehsil Kandaghat, Distt. Shimla were inspected on 30-11-2015 with reference to their application no Nil dated usher, Nil by the Incharge, Fire Station Tilaknagar, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.28-01-2016 to 27-01-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Proprietor  
Laxmi Stone Crusher, Village Lachog, P.O. Soghi,  
Tehsil & Distt. Shimla H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Rampur Public School V.P.O. Nogli, Tehsil Rampur were inspected on 28-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 28-01-2016 to 27-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Rampur Public School V.P.O. Nogli,**  
**Tehsil Rampur, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of School for Visually Impaired Children Dhalli, Shimla were inspected on 20-01-2016 with reference to their application no. Nil dated Nil by the Station Fire Officer, Fire Station Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 28-01-2016 to 27-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
School for Visually Impaired Children Dhalli,  
Shimla, Distt. Shimla, H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Himalayan Public Sr.Sec.School Rohru were inspected on 23-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 30-01-2016 to 29-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Himalayan Public Sr.Sec.School Rohru,**  
**Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of Shivalik Public School Chirgaon, Tehsil Rohru were inspected on 30-11-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 30-01-2016 to 29-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Shivalik Public School Chirgaon,**  
**Tehsil Rohru, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of **S.D. Public High School Nerwa, Tehsil Chopal** were inspected on **16-12-2015** with reference to their application no. **Nil** dated **Nil** by the **Incharge, Fire Station Rohru** with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 30-01-2016 to 29-01-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: **Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**S.D. Public High School Nerwa,**  
**Tehsil Chopal, Distt. Shimla, H.P.**



**TO WHOM IT MAY CONCERN**

That the premises of Ras Resort Pvt. Ltd. Village Galu, Near Kufri, Shimla were inspected on 8-01-2016 with reference to their application no Nil dated usher, Nil by the Incharge, Fire Station Chhota Shimla, with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.2-02-2016 to 1-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Proprietor**  
**Ras Resort Pvt. Ltd. Village Galu,**  
**Near Kufri, Shimla, Distt. Shimla H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of Gurukul Public School Gopal Pur (Dobi), P.O. Kartot, Tehsil Rampur were inspected on 9-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 8-02-2016 to 7-02-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**Gurukul Public School Gopal Pur (Dobi), P.O. Kartot,**  
**Tehsil Rampur, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of D.A.V. Centenary Public School Theog, Distt. Shimla were inspected on 29-01-2016 with reference to their application no. DAV THEOG/ 307/23015-16 dated 2-01-2016 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 8-02-2016 to 7-02-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,**  
**D.A.V. Centenary Public School Theog,**  
**Tehsil Theog, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-1184 dated 09-02-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Kotkhai Public School Kotkhai were inspected on 1-02-2016 with reference to their application no. KPS. 16/2015 dated 30-12-2015 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 9-02-2016 to 8-02-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Kotkhai Public School Kotkhai,  
Tehsil Kotkhai, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of Raj Kids Palace Public School VPO Rampur were inspected on 30-01-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 9-02-2016 to 8-02-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Raj Kids Palace Public School VPO Rampur,  
Tehsil Rampur, Distt. Shimla, H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Roots Country School Baghi, Tehsil Kotkhai, were inspected on 31-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 10-02-2016 to 9-02-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Roots Country School Baghi,  
Tehsil Kotkhai, Distt. Shimla, H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Prakash Tea Stall, Tawi Mode Totu, Shimla were inspected 20-01-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.17-02-2016 to 16-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,  
The Proprietor  
Prakash Tea Stall,  
Tawi Mode Totu, Shimla H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Hotel Anfield, Near Victory Tunnel, Shimla were inspected 4-02-2016 with reference to their application no. Nil dated 7-01-2016 by the Divisional Fire Officer, Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.17-02-2016 to 16-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager  
Hotel Anfield, Near Victory Tunnel,  
Shimla H.P. 171003**



**TO WHOM IT MAY CONCERN**

That the premises of Prakash Furniture Factory, Near Victory Tunnel Shimla-171003 were inspected 4-02-2016 with reference to their application no. Nil dated 5-01-2016 by the Divisional Fire Officer, Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.23-02-2016 to 22-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

**Chief Fire Officer,**  
**Himachal Pradesh Shimla-2**

To,  
The Manager  
Prakash Furniture Factory,  
Near Victory Tunnel Shimla-171003

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-1801 dated 02-03-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Hotel Ashiana Regency Chhota Shimla were inspected 25-02-2016 with reference to their application no. Nil dated 8-01-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.2-02-2016 to 1-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager  
Hotel Ashiana Regency,  
Chhota Shimla, Shimla-171002**

**TO WHOM IT MAY CONCERN**

That the premises of Shimla Bhojnalya Khalini, Shimla-2 were inspected 1-03-2016 with reference to their application no. Nil dated 2-02-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e.2-02-2016 to 1-02-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,  
The Manager  
Shimla Bhojnalya Khalini,  
Shimla-171002

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-2002 dated 08-03-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Hills International Public High School Jubbal, Distt. Shimla were inspected on 4-02-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 8-03-2016 to 7-03-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Hills International Public High School Jubbal,  
Tehsil Jubbal, Distt. Shimla, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-2003 dated 08-03-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Divya Lok Public School Anni, V.P.O. & Tehsil Anni were inspected on 18-02-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 8-03-2016 to 7-03-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Divya Lok Public School Anni,  
V.P.O. & Tehsil Anni, Distt. Kullu, H.P.**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-2417 dated 23-30-2016 Shimla-2**

**TO WHOM IT MAY CONCERN**

**That the premises of Usha Memorial Public School Baral, Tehsil Rohru were inspected on 28-02-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.**

**That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-03-2016 to 18-03-2018) subject to fulfillment of the following conditions:-**

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.**
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.**
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.**

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,**

**The Principal,  
Usha Memorial Public School Baral,  
Tehsil Rohru, Distt. Shimla, H.P**

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC- dated Shimla-2**

**TO WHOM IT MAY CONCERN**

That the premises of Princeton School Phase-III, Sec.-V, BCS New Shimla were inspected on 15-03-2016 with reference to their application no. 472 dated 26-12-2015 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-03-2016 to 18-03-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,

**The Principal,  
Princeton School Phase-III, Sec.-V,  
B.C.S. New Shimla, Distt. Shimla, H.P.**

**TO WHOM IT MAY CONCERN**

That the premises of Oberoi Hotels Pvt. Ltd. , Clarkes Hotel, The Mall Shimla were inspected 18-02-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.23-03-2016 to 22-03-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

**Remarks: Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Manager  
Oberoi Hotels Pvt. Ltd. ,  
Clarkes Hotel, The Mall Shimla-171001**



TO WHOM IT MAY CONCERN

That the premises of Raj Sweet Shop Tutikandi Shimla were inspected 18-03-2016 with reference to their application no. Nil dated 3-03-2016 by the Incharge, Fire Station Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e. 28-03-2016 to 27-03-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained within the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Tilak Raj  
Raj Sweet Shop Tutikandi,  
Shimla-171004

TO WHOM IT MAY CONCERN

That the premises of Krishna Coal Co. Shop No. 6, Panchayat Bhawan, Shimla were inspected 25-01-2016 with reference to their application no. Nil dated 21-01-2016 by the Incharge, Fire Station Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.31-03-2016 to 30-03-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Krishna Coal Co. Shop No. 6,  
Panchayat Bhawan, Shimla-171001

TO WHOM IT MAY CONCERN

That the premises of Hotel Aangan Regency, Near ISBT, Tutikandi, Shimla-4 were inspected 18-03-2016 with reference to their application no. Nil dated 16-02-2016 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.31-03-2016 to 30-03-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Hotel Aangan Regency  
Near ISBT, Tutikandi, Shimla-4

TO WHOM IT MAY CONCERN

That the premises of Krishna Coal Company, Cart Road, Bus Stand Shimla were inspected 25-01-2016 with reference to their application no. Nil dated 21-01-2016 by the Incharge, Fire Station Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.31-03-2016 to 30-03-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Krishna Coal Company,  
Cart Road, Bus Stand, Shimla-171001

TO WHOM IT MAY CONCERN

That the premises of National Public School New Shimla were inspected on 22-03-2016 with reference to their application no. Nil dated 21-03-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 2-04-2016 to 1-04-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
National Public School New Shimla,  
Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Dhrub Public High School Dhamwari, Tehsil Chirgaon were inspected on 15-03-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 2-04-2016 to 1-04-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Dhrub Public High School Dhamwari,  
Tehsil Chirgaon, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir High School Pujarli No. 4, Tehsil Tikkar, Distt. Shimla were inspected on 18-03-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 2-04-2016 to 1-03-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Dhrub Public High School Dhamwari,  
Tehsil Chirgaon, Distt. Shimla, H.P.

**DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2**  
**No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-3492 dated 07-04-2016 Shimla-2**

## TO WHOM IT MAY CONCERN

That the premises of Rampur Gas Agency, Village Mauja Kalan, P.O. Nogli, Tehsil Rampur were inspected on 5-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.7-04-2016 to 6-04-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment /system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. You are advised to comply with the storage rule laid down by the Chief Controller of explosive with latest amendment, failing which this certificate shall be treated as cancelled.

Remarks: **Good House keeping must be maintained with in the premises.**

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

**To,  
The Proprietor,  
Rampur Gas Agency, Village Mauja Kalan,  
P.O. Nogli Tehsil Rampur, Distt. Shimla H.P.**



TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir High School Pujarli No. 4, Tehsil Tikkar, Distt. Shimla were inspected on 18-03-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 2-04-2016 to 1-03-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Dhrub Public High School Dhamwari,  
Tehsil Chirgaon, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Adarsh Public School Digerh VPO Digerh, Tehsil Anni were inspected on 7-12-2015 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 7-04-2016 to 6-04-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Adarsh Public School Digerh VPO Digerh,  
Tehsil Anni, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Kamna Hill Resorts Summer Hill, were inspected 25-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.02-05-2016 to 30-04-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Kamna Hill Resorts Summer Hill,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Jeevan Jyoti Vidya Niketan Anant Vihar, Narkanda, Distt. Shimla were inspected on 2-04-2016 with reference to their application no. Nil dated 01-04-2016 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 5-05-2016 to 4-05-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Jeevan Jyoti Vidya Niketan Anant Vihar,  
Narkanda, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Grace, Shankli, Shimla, were inspected 09-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, The Mall Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.10-05-2016 to 09-05-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Hotel Grace, Shankli, Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Rama Palace, 5, Elfin Estate Chaura Maidan, Shimla-4, were inspected 22-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.10-05-2016 to 09-05-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Hotel Rama Palace, 5, Elfin Estate Chaura Maidan,  
Shimla-4, H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Jeori Public School VPO Jeori, Tehsil Rampur were inspected on 16-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 17-05-2016 to 16-05-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Jeori Public School VPO Jeori,  
Tehsil Rampur, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Adarsh Public School Digerh, VPO Digerh, Tehsil Anni, Distt. Kullu were inspected on 2-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 24-05-2016 to 23-05-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Adarsh Public School Digerh, VPO Digerh,  
Tehsil Anni, Distt. Kullu, H.P.



TO WHOM IT MAY CONCERN

That the premises of Kamna Public Middle School Tara Bhawan, Lower Khalini, Shimla were inspected on 20-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Kamna Public Middle School Tara Bhawan,  
Lower Khalini, Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Silverine, Near High Court, The Mall Shimla were inspected 18-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, The Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor  
Hotel Silverine, Near High Court,  
The Mall Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Buddy's Food Joint, Forest View Building Murray Field Estate, Shimla-2 were inspected 10-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, The Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Buddy's Food Joint, Forest View Building,  
Murray Field Estate, Shimla-2, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Kuldeep Singh Canteen, D.A.V Primary School Middle Bazar, Shimla were inspected on 20-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

Sh. Kuldeep Singh,  
Kuldeep Singh Canteen, D.A.V Primary School ,  
Middle Bazar, Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Kuldeep Singh Canteen, D.A.V Primary School Middle Bazar, Shimla were inspected on 20-04-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

Sh. Kuldeep Singh,  
Kuldeep Singh Canteen, D.A.V Primary School ,  
Middle Bazar, Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shimla Sanitarium & Hospital Carton House, Chaura Maidan Shimla-4 were inspected 22-04-2016 with reference to their application no. Fire/2016/001 dated 22-04-2014 by the Incharge, Fire Station, Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Shimla Sanitarium & Hospital Carton House,  
Chaura Maidan Shimla-4, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Ridge International Public School Chairgaon, Distt Shimla were inspected on 11-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Ridge International Public School Chairgaon,  
Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Aryan Public School Village Gharyana, P.O Sunni, Tehsil Sunni, Distt Shimla was inspected on 04-06-2016 with reference to his application no. APS-NOC/2016-17 dated 13-04-2016 by the D.F.O Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 09-06-2016 to 08-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Aryan Public School Village Gharyana,  
P.O Sunni, Tehsil Sunni, Distt Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises Happy Model High School Sanjauli Chowk Shimla, Distt Shimla was inspected on 31-05-2016 with reference to his application no. Nil dated Nil by the Incharge Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 09-06-2016 to 08-06-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Happy Model High School Sanjauli Chowk Shimla,  
Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Rock Castle Near Kachi Ghatti, Shimla, Distt. Shimla was inspected 30-05-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station, Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.16-06-2016 to15-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel Rock Castle Near Kachi Ghatti,  
Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Natraj Bar & Restaurant, Chhota Shimla, Distt. Shimla was inspected 07-06-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station, Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.16-06-2016 to15-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Natraj Bar & Restaurant, Chhota Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Kufri Hotels Pvt. Ltd. V.P.O Kufri, Distt. Shimla was inspected 28-05-2016 with reference to his application no. Nil dated 25-02-2016 by the Incharge, Fire Station, Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.16-06-2016 to15-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Kufri Hotels Pvt. Ltd. V.P.O Kufri,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Groom Bridge Guest House, Bharari, Distt. Shimla was inspected 27-05-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station, Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.29-06-2016 to 28-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Groom Bridge Guest House, Bharari,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of AGM/HOP (Const) SJVNL Shanahan Malyana, Shimla, Distt. Shimla was inspected 18-04-2016 with reference to his application no. SJVN/CCC-12/ 2016-1204 dated 02-02-2016 by the Incharge, Fire Station, Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.06-07-2016 to 05-07-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
AGM/HOP (Const) SJVNL Shanahan Malyana,  
Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Arya Girls Sr. Sec. School Shimla-1, Distt Shimla was inspected on 01-07-2016 with reference to his application no. Nil dated 27-06-2016 by the Incharge Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 06-07-2016 to 05-07-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Arya Girls Sr. Sec. School Shimla-1,  
Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Hainault Public School Near Benmore, Chhota Shimla, Distt Shimla was inspected on 29-06-2016 with reference to his application no. Nil dated Nil by the Incharge Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 08-07-2016 to 07-07-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Hainault Public School Near Benmore,  
Chhota Shimla, Distt Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Buddy's Food Joint, Forest View Building Murray Field Estate, Shimla-2 were inspected 10-05-2016 with reference to their application no. Nil dated Nil by the Incharge, Fire Station, The Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-06-2016 to 03-06-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Maninder Singh,  
Buddy's Food Joint, Forest View Building,  
Murray Field Estate, Shimla-2, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Trinity International School Fagu, Distt Shimla was inspected on 08-07-2016 with reference to his application no. Nil dated Nil by the Incharge Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 12-07-2016 to 11-07-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Trinity International School Fagu,  
Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Shimla P.G. Collage of Education Sheetal Kunj Estate, P.O. Kamla Nagar, Sanjauli, Distt Shimla was inspected on 09-07-2016 with reference to his application no. Nil dated Nil by the Incharge Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 13-07-2016 to 12-07-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Shimla P.G. Collage of Education Sheetal Kunj Estate,  
P.O Kamla Nagar, Sanjauli, Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises Spring Dale School, V.P.O Khaneri, Tehsil Rampur, Distt Shimla was inspected on 03-06-2016 with reference to his application no. Nil dated Nil by the Incharge Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 16-07-2016 to 15-07-2018) subject to fulfillment of the following conditions:-

- 1 That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
- 2 That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
- 3 Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,

The Principal,  
Spring Dale School, V.P.O Khaneri,  
Tehsil Rampur, Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Agma International School Phase-III, Sec.-V, BCS New Shimla was inspected on 15-03-2016 with reference to his application no. 472 dated 26-12-2015 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-03-2016 to 18-03-2018) subject to fulfillment of the following conditions:-

1. Previous NOC issued vide this office letter of even number 2333 dated 21-03-2016 shall be treated as cancelled
2. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
3. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
4. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Agma International School Phase-III, Sec.-V,  
BCS New Shimla, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Buddy's Food Joint, Forest View Building Murray Field Estate, Shimla-2 was inspected 12-07-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station, The Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.26-07-2016 to 25-07-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Jaspreet Singh,  
Buddy's Food Joint, Forest View Building,  
Murray Field Estate, Shimla-2, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of K.S Café Karol Sons, S.D.A Complex, Shop No. 33, BlockNo.-6, Kasumpti, Shimla-9 was inspected 15-07-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station, The Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.26-07-2016 to 25-07-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Jaspreet Singh,  
K.S Café Karol Sons, S.D.A Complex, Shop No. 33,  
BlockNo.-6, Kasumpti, Shimla-9, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sunny Canteen Below Hotel Himachal, Near Old Bus Stand Shimla was inspected 30-05-2016 with reference to his application no. Nil dated 12-05-2016 by the Incharge, Fire Station, Mall Road, Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.27-07-2016 to 26-07-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Sunny Canteen Below Hotel Himachal,  
Near Old Bus Stand Shimla, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Grammar School, Swaroop Bhawan Upper Kaithu, Shimla was inspected on 30-06-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road, Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 10-08-2016 to 09-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Grammar School, Swaroop Bhawan Upper Kaithu,  
Shimla, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Agma International School Phase-III, Sec.-V, BCS New Shimla was inspected on 15-03-2016 with reference to his application no. 472 dated 26-12-2015 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-03-2016 to 18-03-2018) subject to fulfillment of the following conditions:-

1. Previous NOC issued vide this office letter of even number 2333 dated 21-03-2016 shall be treated as cancelled
2. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
3. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
4. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Agma International School Phase-III, Sec.-V,  
BCS New Shimla, Distt. Shimla, H.P.

TO WHOM IT MAY CONCERN

That the premises of Trishool Guest House, Near Victory Tunnel Shimla, Distt. Shimla was inspected 01-08-2016 with reference to his application no. Nil dated 11-07-2016 by the Divisional Fire Officer, Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.11-08-2016 to 10-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Trishool Guest House, Near Victory Tunnel Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of CK Infrastructure Ltd. SRS Cinemas (A Unit of SRS Ltd.) 2<sup>nd</sup> Floor, CK Mall, New ISBT, Tutikandi, Shimla, Distt. Shimla was inspected 25-07-2016 with reference to his application no. Nil dated 23-07-2016 by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.11-08-2016 to 10-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
CK Infrastructure Ltd. SRS Cinemas (A Unit of SRS Ltd.) 2<sup>nd</sup> Floor,  
CK Mall, New ISBT, Tutikandi, Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sanskriti School Ghanahatti, Tehsil & Distt. Shimla was inspected on 16-08-2016 with reference to his application no. 06 dated 28-07-2016 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 18-08-2016 to 17-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sanskriti School Ghanahatti,  
Tehsil & Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sharma Bhojnalya, Near A.G Office Shimla, Distt. Shimla was inspected 23-07-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.24-08-2016 to 23-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Roshan Lal Sharma (Owner),  
Sharma Bhojnalya, Near A.G Office Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of North Point School Jawala Mata Mandir Road Bhattakuffer, Shimla, Distt. Shimla was inspected on 18-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 27-08-2016 to 26-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
North Point School Jawala Mata Mandir,  
Road Bhattakuffer, Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Goofa Ashiana Complex, The Ridge Shimla, Distt. Shimla was inspected 10-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.27-08-2016 to 26-08-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Goofa Ashiana Complex, The Ridge Shimla,  
Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Taksshila Public School Kuftu, Tehsil Kandaghat , Distt. Solan was inspected on 04-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 09-09-2016 to 08-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The President,  
Taksshila Public School Kuftu,  
Tehsil Kandaghat , Distt. Solan H.P.

TO WHOM IT MAY CONCERN

That the premises of Krishna Lodge, 31 Lower Bazar, Shimla-1, Distt. Shimla was inspected 31-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.16-09-2016 to 15-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Krishna Lodge, 31 Lower Bazar, Shimla-1,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Dharam Chhand Sharma, Chat Shop No-06, Near Kalka Shimla Taxi Union, Old Bus Stand Shimla-1, was inspected 08-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.16-09-2016 to 15-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Dharam Chhand Sharma, Chat Shop No-06,  
Near Kalka Shimla Taxi Union, Old Bus Stand Shimla-1,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Ankur Day School Near Brock Host, Palm Cottage Shimla-9, was inspected on 12-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-09-2016 to 19-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The President,  
Ankur Day School Near Brock Host,  
Palm Cottage Shimla-9, Distt. Solan H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Woodrina Kufri Road Dhalli, Shimla-12, Distt. Shimla was inspected 21-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.23-09-2016 to 22-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Hotel Woodrina Kufri Road Dhalli, Shimla-12,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Rampur HPS, Bayal, P.O Koyal, Tehsil Nirmand, Distt. Kullu was inspected 20-09-2016 with reference to his application no. SJVN/RHPS/Safety/f-71/16-769 dated 02-07-2016 by the Divisional Fire Officer, Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.27-09-2016 to 26-09-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Rampur HPS, Bayal, P.O Koyal,  
Tehsil Nirmand, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Starlite Dyers & Drycleaners, No. 38-39/1, The Mall Shimla, Distt. Shimla was inspected 19-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.03-10-2016 to 02-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Starlite Dyers & Drycleaners, No. 38-39/1,  
The Mall Shimla, Distt. Shimla H.P.





TO WHOM IT MAY CONCERN

That the premises of D.R Ambition Public School Village Kholighat, P.O Jahoo, Sub-Tehsil Nankhari, Distt. Shimla was inspected on 09-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 03-10-2016 to 02-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
D.R Ambition Public School Village Kholighat,  
P.O Jahoo, Sub-Tehsil Nankhari, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Adarsh Public High School Chirgaon, Tehsil Chirgaon, Distt. Shimla was inspected on 13-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 06-10-2016 to 05-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Adarsh Public High School Chirgaon,  
Tehsil Chirgaon, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Gramodaya Vidhya Mandir Masli, Tehsil Chirgaon, Distt. Shimla was inspected on 13-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 06-10-2016 to 05-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Gramodaya Vidhya Mandir Masli,  
Tehsil Chirgaon, Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8155 dated 17-10-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Blue Bells Public School Dhalli, Shimla-12, Distt. Shimla was inspected on 04-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-10-2016 to 14-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Blue Bells Public School Dhalli,  
Shimla-12, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Aryansh Vidya Mandir Raghupur, V.P.O Kothi, Tehsil Anni, Distt. Kullu was inspected on 12-08-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 20-10-2016 to 19-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Aryansh Vidya Mandir Raghupur,  
V.P.O Kothi, Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of B.M. Moters, Chhota Shimla, Distt. Shimla was inspected 13-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.20-10-2016 to 19-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
B.M. Moters, Chhota Shimla,  
Distt. Shimla H.P.

**TO WHOM IT MAY CONCERN**

That the premises of H.D. Public School Janedghat, Sub Tehsil Junga was inspected on 10-10-2016 with reference to his application no. HDPS/24/2016 dated 14-10-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 22-10-2016 to 21-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
H.D. Public School Janedghat,  
Sub Tehsil Junga, Distt. Shimla H.P.

**TO WHOM IT MAY CONCERN**

That the premises of Venus Public Sr.Sec. School Neether, V.P.O. & Sub Tehsil Nither was inspected on 21-10-2016 with reference to their application no. Nil dated 21-10-2016 by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e.22-10-2016 to 21-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

**Chief Fire Officer,  
Himachal Pradesh Shimla-2**

To,  
The Principal,  
Venus Sr.Sec. School Neether,  
V.P.O. & Sub Tehsil Nither, Distt . Kullu H.P.



DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8323 dated 26-10-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Stokes Memorial School Junga Road Pujarli, Tehsil & Distt. Shimla was inspected on 20-10-2016 with reference to his application no. SMS/FIRE/2016/377 dated 27-06-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 27-10-2016 to 26-10-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Stokes Memorial School Junga Road Pujarli,  
Tehsil & Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8435 dated 04-11-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Sanjay Gandhi Public Sr. Sec. School New Shimla-9, Distt. Shimla was inspected on 14-10-2016 with reference to his application no. SGPS/340/2016 dated 07-10-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 02-11-2016 to 01-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sanjay Gandhi Public Sr. Sec. School New Shimla-9,  
Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8436 dated 04-11-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Ganga Public School Bhagwati Nagar, Lower Khalini, Distt. Shimla was inspected on 13-10-2016 with reference to his application no. Nil dated 06-10-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 02-11-2016 to 01-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Ganga Public School Bhagwati Nagar,  
Lower Khalini, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shalini Public School Khatnol, Tehsil Sunni, Distt. Shimla was inspected on 18-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 02-11-2016 to 01-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Shalini Public School Khatnol,  
Tehsil Sunni, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Monal Public School Near Old Police Chowki Sanjauli-6, Distt. Shimla was inspected on 27-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 02-11-2016 to 01-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Monal Public School Near Old Police Chowki,  
Sanjauli-6, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Monal Public Sr. Sec. School Sanjauli-6,  
Near Sanjauli Chowk, Distt. Shimla was inspected on 27-10-2016 with reference to his  
application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to  
measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant  
at his premises were found satisfactory at the time of inspection. Hence, No Objection  
Certificate is issued/ renewed in his favour for Two years(i.e. 02-11-2016 to 01-11-  
2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to  
handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the  
fire fighting equipment/ system in perfect running condition, failing which this  
certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in  
every three months and written record shall be kept in the premises for the  
inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local  
Fire Officer during annual day function or any other function in the school  
where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Monal Public Sr. Sec. School Sanjauli-6,  
Near Sanjauli Chowk, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Hill Top, Near SBI, The Mall Shimla, Distt. Shimla was inspected 13-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-11-2016 to 03-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel Hill Top, Near SBI, The Mall Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Thakur Dass C/o Akshay Kumar, Near Bus Stand Kasumpti -9, Distt. Shimla was inspected 13-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.04-11-2016 to 03-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Thakur Dass C/o Akshay Kumar,  
Near Bus Stand Kasumpti -9, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Gurukul Public School Deha(Balson), Tehsil Theog, Distt. Shimla was inspected on 19-10-2016 with reference to his application no. Nil dated 21-10-2016 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 07-11-2016 to 06-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Gurukul Public School Deha (Balson),  
Tehsil Theog, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sunshine Public School Sainj, Tehsil Theog, Distt. Shimla was inspected on 19-10-2016 with reference to his application no. Nil dated 03-10-2016 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 07-11-2016 to 06-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sunshine Public School Sainj,  
Tehsil Theog, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Padmawati Saraswati Vidya Mandir High School Matiana, Tehsil Theog, Distt. Shimla was inspected on 19-10-2016 with reference to his application no. Nil dated 07-10-2016 by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 07-11-2016 to 06-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Padmavati Saraswati Vidya Mandir High School Matiana,  
Tehsil Theog, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir School Behli, P.O Sunder Nagar, Distt Mandi was inspected on 02-11-2016 with reference to his application no. Nil dated 30-09-2016 by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-11-2016 to 14-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir School Behli,  
P.O Sunder Nagar, Distt Mandi H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir School Tattapani, Tehsil Karsog, Distt Mandi was inspected on 18-10-2016 with reference to his application no. Nil dated 28-09-2016 by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-11-2016 to 14-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir School Tattapani,  
Tehsil Karsog, Distt Mandi H.P.

TO WHOM IT MAY CONCERN

That the premises of Shalini Public School Kangal, Tehsil Kumarsain, Distt Shimla was inspected on 17-10-2016 with reference to his application no. Nil dated 06-09-2016 by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-11-2016 to 14-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Head Teacher,  
Shalini Public School Kangal,  
Tehsil Kumarsain, Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Ivy International School Near Kamla Nagar, Chakrayal, Bhatakufer, Distt Shimla was inspected on 03-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-11-2016 to 14-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Ivy International School Near Kamla Nagar,  
Chakrayal, Bhatakufer, Distt Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8638 dated 17-11-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Rashtriya Vidya Kender Kasumpati Shimla-9, Distt Shimla was inspected on 05-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-11-2016 to 14-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Rashtriya Vidya Kender Kasumpati Shimla-9,  
Distt Shimla H.P.



DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8709 dated 18-11-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Chapslee Senior School North Wood, Bharari Road Shimla, Distt Shimla was inspected on 27-10-2016 with reference to his application no. Nil dated 25-10-2016 by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-11-2016 to 18-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Chapslee Senior School North Wood,  
Bharari Road Shimla, Distt Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8608 dated 19-11-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Chapslee Junior School Elysium Hill, Near Logwood Shimla, Distt Shimla was inspected on 27-10-2016 with reference to his application no. Nil dated 25-10-2016 by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 19-11-2016 to 18-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Chapslee Junior School Elysium Hill,  
Near Logwood Shimla, Distt Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Classic Opposite Railway Board Building, The Mall Shimla, Distt. Shimla was inspected 25-10-2016 with reference to his application no. Nil dated Nil by the Divisional Fire Officer, Fire Division Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.21-11-2016 to 20-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Hotel Classic Opposite Railway Board Building,  
The Mall Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Monson Café, Shop No. 72, Block-10, SDA Complex Kasumpti Shimla-9, Distt. Shimla was inspected 14-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years (i.e.25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Sudershan Sood,  
Monson Café, Shop No. 72, Block-10,  
SDA Complex Kasumpti Shimla-9, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Venus Public Sr. Sec. School V.P.O Neether, Distt. Kullu was inspected on 21-10-2016 with reference to his application no. Nil dated 21-10-2016 by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Venus Public Sr. Sec. School V.P.O Neether,  
Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Shivalik Institute of Nursing Chhibber Complex Kamla Nagar, Sanjauli, Shimla-6, Distt. Shimla was inspected on 17-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shivalik Institute of Nursing,  
Chhibber Complex Kamla Nagar,  
Sanjauli, Shimla-6, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Living Values Public School Chopal, Tehsil Chopal, Distt. Shimla was inspected on 19-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Living Values Public School Chopal,  
Tehsil Chopal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sun Shine Public School Village Padampur, Tehsil Rampur, Distt. Shimla was inspected on 24-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sun Shine Public School Village Padampur,  
Tehsil Rampur, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Sun Shine Public School Village Brow, P.O Rampur, Tehsil Nirmond, Distt. Kullu was inspected on 24-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sun Shine Public School Village Brow, P.O Rampur,  
Tehsil Nirmond, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Five Star Public High School Mandal, Tehsil Jubbal, Distt. Shimla was inspected on 01-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Five Star Public High School Mandal,  
Tehsil Jubbal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shaheed Bhagat Singh, Public High School Battar Gallu, Tehsil Jubbal, Distt. Shimla was inspected on 01-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shaheed Bhagat Singh,  
Public High School Battar Gallu,  
Tehsil Jubbal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Pioneer Public School Rai Sharan, P.O Dansa Tehsil Rampur, Distt. Shimla was inspected on 14-09-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 25-11-2016 to 24-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Pioneer Public School Rai Sharan,  
P.O Dansa Tehsil Rampur, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Maheshwari Public School Cheog, Tehsil Theog Distt. Shimla was inspected on 04-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 29-11-2016 to 28-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Maheshwari Public School Cheog,  
Tehsil Theog Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Campus Public School Sarog, Tehsil Theog Distt. Shimla was inspected on 29-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 29-11-2016 to 28-11-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Campus Public School Sarog,  
Tehsil Theog Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Himalayan Primary School Education Society Upper Kaithu, Shimla, Distt. Shimla was inspected on 28-11-2016 with reference to his application no. Nil dated 18-10-2016 by the Incharge, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 05-12-2016 to 04-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Himalayan Primary School Education Society Upper Kaithu,  
Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Harmony Public High School Rohru, Distt. Shimla was inspected on 15-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 05-12-2016 to 04-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Harmony Public High School Rohru,  
Distt. Shimla H.P.



DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-8959 dated 05-12-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir Middle School Tikkar, Tehsil Rohru, Distt. Shimla was inspected on 15-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 05-12-2016 to 04-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir Middle School Tikkar,  
Tehsil Rohru, Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-9035 dated 09-12-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Savitri Public School Summer Seat Shimla, Distt. Shimla was inspected on 03-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 07-12-2016 to 06-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmistress,  
Savitri Public School Summer Seat Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Himalayan Public High School Theog, Distt. Shimla was inspected on 21-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 07-12-2016 to 06-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Himalayan Public High School Theog,  
Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-9091 dated 15-12-2016 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of H.P.U Model School Summer Hill, Shimla-5, Distt. Shimla was inspected on 14-12-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 15-12-2016 to 14-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
H.P.U Model School Summer Hill, Shimla-5,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Blue Bells Public School Shoghi, Shimla was inspected on 19-11-2016 with reference to his application no. 002 dated 1-10-2016 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for Two years(i.e. 09-12-2016 to 08-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Blue Bells Public School Shoghi, Shimla,  
Distt. Shimla H.P.-171219

TO WHOM IT MAY CONCERN

That the premises of Divyalok Public School Village New Tikri, P.O Arsu, Tehsil Nirmand, Distt. Kullu was inspected on 21-10-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 16-12-2016 to 15-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Divyalok Public School Village New Tikri,  
P.O Arsu, Tehsil Nirmand, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Zion Holidays Pvt. Ltd. Near Sanket Mochan Temple Shimla, Distt. Shimla was inspected 05-12-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.16-12-2016 to 15-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
M/s Zion Holidays Pvt. Ltd.  
Near Sanket Mochan Temple Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of J.K.M. Public School Matiana, Distt. Shimla was inspected on 19-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 21-12-2016 to 20-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
J.K.M. Public School Matiana,  
Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Snow Lotus Hotel, Near Sanket Mochan Mandir Shimla, Distt. Shimla was inspected 12-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.21-12-2016 to 20-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Snow Lotus Hotel,  
Near Sanket Mochan Mandir Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Daffodil Resorts (P) Ltd. Near Distt. Court Complex, Chakkar, Shimla-5, Distt. Shimla was inspected 07-12-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.21-12-2016 to 20-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel Daffodil Resorts (P) Ltd.  
Near Distt. Court Complex, Chakkar,  
Shimla-5, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Silver Bells Public Primary School Rohru, Tehsil Rohru, Distt. Shimla was inspected on 28-11-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 22-12-2016 to 21-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Silver Bells Public Primary School Rohru,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Greenwood House School Ratnari, Distt. Shimla was inspected on 21-12-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Theog with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 24-12-2016 to 23-12-2018) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Greenwood House School Ratnari,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Tata Tele Services Limited Kasumpti, Shimla-9, Distt. Shimla was inspected 02-01-2017 with reference to his application no. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.20-01-2017 to 19-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Tata Tele Services Limited Kasumpti,  
Shimla-9, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Shimla Green's, Village Gahan, Summer Hill, Shimla-5 Distt. Shimla was inspected 24-12-2016 with reference to his application no. Nil dated 05-12-2016 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprioter,  
Hotel Shimla Green's, Village Gahan,  
Summer Hill, Shimla-5 Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir School Sunni, Tehsil Sunni, Distt. Shimla was inspected on 12-12-2016 with reference to his application no. Nil dated 18-10-2016 by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir School Sunni,  
Tehsil Sunni, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Nishant Public High School Basantpur, Tehsil Sunni, Distt. Shimla was inspected on 17-12-2016 with reference to his application no. Nil dated Nil by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Nishant Public High School Basantpur,  
Tehsil Sunni, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Gita Niketan Vidyalaya Sunni, Tehsil Sunni, Distt. Shimla was inspected on 19-12-2016 with reference to his application no. Nil dated 21-10-2016 by the Incharge, Fire Post Sunni with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Gita Niketan Vidyalaya Sunni,  
Tehsil Sunni, Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-417 dated 28-01-2017 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Swaran Public High School Tuti Kandi, Shimla, Distt. Shimla was inspected on 22-12-2016 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Swaran Public High School Tuti Kandi,  
Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sh. Jagdish Ram Welding Works, Dleep Sood Building, Sood Bhawan Gingiri Lower Khalini, Distt. Shimla was inspected 26-12-2016 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Jagdish Ram (Welding Works),  
Dleep Sood Building, Sood Bhawan Gingiri Lower Khalini,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of DAV Mahatma Anand Swami Public School Totu, Shimla-11, Distt. Shimla was inspected on 11-01-2017 with reference to his application No. DAV Totu/16-17/3384 dated 09-01-2017 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmistress,  
DAV Mahatma Anand Swami Public School Totu,  
Shimla-11, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Dr. Lal Path Labs Ltd. Sarab Complex, Main Market Sanjauli, Shimla-06, Distt. Shimla was inspected 06-01-2017 with reference to his application No. Nil dated 06-01-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Dr. Lal Path Labs Ltd.  
Sarab Complex, Main Market Sanjauli,  
Shimla-06, Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-420 dated 28-01-2017 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Tractors India Pvt. Ltd. Near Shiv Gufa Mandir, N.H-22 By Pass Road, Malayana, Shimla-06, Distt. Shimla was inspected 16-01-2017 with reference to his application No. Nil dated 06-01-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.23-01-2017 to 22-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Dinesh Palwal,  
Tractors India Pvt. Ltd, Near Shiv Gufa Mandir,  
N.H-22 By Pass Road, Malayana,  
Shimla-06, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sharma Dhaba Shop No-1, Chhota Shimla Chowk, Distt. Shimla was inspected 15-01-2017 with reference to his application No. Nil dated 12-01-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.24-01-2017 to 23-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Smt. Biasa Devi.  
Sharma Dhaba Shop No-1,  
Chhota Shimla Chowk, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Canteen O/o Directorate of Consolidation of Holdings, S.D.A Complex Kasumpti, Distt. Shimla was inspected 26-12-2016 with reference to his application No. Nil dated 02-12-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.24-01-2017 to 23-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Dinesh Kumar S/o Sh. Thakur Ram,  
Canteen O/o Directorate of Consolidation of Holdings,  
S.D.A Complex Kasumpti, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Himalyan Sr. Sec. Public School Nerwa, Tehsil Chopal, Distt. Shimla was inspected on 02-01-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Post Chopal with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-01-2017 to 26-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Himalyan Sr. Sec. Public School Nerwa,  
Tehsil Chopal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Vivekanand Public School V.P.O Chowai, Tehsil Anni, Distt. Kullu was inspected on 09-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-01-2017 to 26-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Vivekanand Public School V.P.O Chowai,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Mandev Air Industries, at IGMC and Hospital Shimla, Distt. Shimla was inspected 27-01-2016 with reference to his application No. Nil dated 23-01-2017 by the Incharge, Fire Station Mall Raod Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e.28-01-2017 to 27-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Mandev Air Industries, at IGMC and Hospital Shimla,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir Middle School Mandal, Tehsil Jubbal, Distt. Shimla was inspected on 06-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 30-01-2017 to 29-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Saraswati Vidya Mandir Middle School Mandal,  
Tehsil Jubbal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Lawrence Public School V.P.O Anni, Tehsil Anni, Distt. Kullu was inspected on 09-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 30-01-2017 to 29-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Lawrence Public School V.P.O Anni,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Shivalik Public School Village Khaneti P.O Batari, Sub-Tehsil Kotgarh, Distt. Shimla was inspected on 14-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 30-01-2017 to 29-01-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shivalik Public School Village Khaneti P.O Batari,  
Sub-Tehsil Kotgarh, Distt. Shimla H.P.

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM (FS) (HQ) 6-10/76-XL –Sml, NOC-551 dated 02-02-2017 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of S.V.M. Public High School V.P.O Dalash, Sub-Tehsil Nithar, Distt. Kullu was inspected on 20-11-2016 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 02-02-2017 to 01-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.V.M. Public High School V.P.O Dalash,  
Sub-Tehsil Nithar, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of S.V.M. Public High School Nither, V.P.O & Sub-Tehsil Nithar, Distt. Kullu was inspected on 29-11-2016 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 06-02-2017 to 05-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.V.M. Public High School Nither,  
V.P.O & Sub-Tehsil Nithar, Distt. Kullu H.P.



TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir School Theog, Tehsil Theog, Distt. Shimla was inspected on 04-02-2017 with reference to application No. Nil dated 01-02-2017 by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 14-02-2017 to 13-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir School Theog,  
Tehsil Theog, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir Primary School Pujarli, No.-03, Tehsil Rohru, Distt. Shimla was inspected on 24-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 14-02-2017 to 13-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir Primary School Pujarli,  
No.-03, Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Blue Bells High School Rohru, Tehsil Rohru, Distt. Shimla was inspected on 26-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 14-02-2017 to 13-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Blue Bells High School Rohru,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Arnav Satvik Vidya Mandir Public School Village Brow, P.O Rampur, Tehsil Nirmand Distt. Kullu was inspected on 10-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-02-2017 to 26-02-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Arnav Satvik Vidya Mandir Public School Village Brow,  
P.O Rampur, Tehsil Nirmand Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Shiksha Mandir Shanan, Distt. Shimla was inspected on 10-02-2017 with reference to application No. 145/16-17 dated 08-01-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 04-03-2017 to 03-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Shiksha Mandir Shanan,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Amar Rising Public School V.P.O Durah, Tehsil Nirmand, Distt. Kullu was inspected on 22-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 07-03-2017 to 06-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Amar Rising Public School V.P.O Durah,  
Tehsil Nirmand, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Semual Stokes Public School V.P.O Kholighat, Sub-Tehsil Kotgarh, Distt. Shimla was inspected on 24-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 07-03-2017 to 06-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Semual Stokes Public School V.P.O Kholighat,  
Sub-Tehsil Kotgarh, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shobha Public School Him Kunj, Dhalli, Shimla-12, Distt. Shimla was inspected on 08-02-2017 with reference to application No. Nil dated 26-12-2016 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 10-03-2017 to 09-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shobha Public School Him Kunj, Dhalli,  
Shimla-12, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir Sr. Sec. School Samoli, Tehsil Rohru, Distt. Shimla was inspected on 25-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 15-03-2017 to 14-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir Sr. Sec. School Samoli,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir High School Chirgaon, Distt. Shimla was inspected on 25-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 15-03-2017 to 14-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir High School Chirgaon,  
Tehsil Chirgaon, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Sholeshwar Public School V.P.O Nankhari, Sub-Tehsil Nankhari, Distt. Shimla was inspected on 20-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 17-03-2017 to 16-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Sholeshwar Public School V.P.O Nankhari,  
Sub-Tehsil Nankhari, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Jai Maa Kali Auto Mobiles Kachi Ghati, Shimla-10, Distt. Shimla was inspected 23-02-2016 with reference to his application No. Nil dated 22-02-2017 by the Incharge, Fire Station Tilaknagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 18-03-2017 to 17-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Jai Maa Kali Auto Mobiles Kachi Ghati,  
Shimla-10, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Saraswati Vidya Mandir Madhawag,  
Tehsil Chopal, Distt. Shimla was inspected on 16-02-2017 with reference to application  
No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted  
for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant  
at his premises were found satisfactory at the time of inspection. Hence, No Objection  
Certificate is issued/ renewed for Two years(i.e. 23-03-2017 to 22-03-2019) subject to  
fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to  
handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the  
fire fighting equipment/ system in perfect running condition, failing which this  
certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in  
every three months and written record shall be kept in the premises for the  
inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local  
Fire Officer during annual day function or any other function in the school  
where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Saraswati Vidya Mandir Madhawag,  
Tehsil Chopal, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shri Sai Caterers Shimla, 6/1, First Floor, The Mall Shimla, Distt. Shimla was inspected 18-03-2016 with reference to his application No. Nil dated Nil by the Incharge, Fire Station The Mall Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 23-03-2017 to 22-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Shri Sai Caterers Shimla, 6/1, First Floor,  
The Mall Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Aanchal Public School Dudhli, Shimla-3, Distt. Shimla was inspected on 16-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station The Mall Road with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-03-2017 to 22-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Managing Director,  
Aanchal Public School Dudhli,  
Shimla-3, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Maheshwari Public School Balag, Tehsil Theog, Distt. Shimla was inspected on 16-03-2017 with reference to application No. Nil dated Nil by the Leading Fireman, Fire Division Shimla-3 with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 23-03-2017 to 22-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Maheshwari Public School Balag,  
Tehsil Theog, Distt. Shimla H.P.



DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM(FS)(HQ)6-10/76-XL –Sml, NOC-1787 dated 24-03-2017 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Leela Indane Gramin Vitrak Pamlahi, Village Lower Pamlahi, P.O Thanedhar, Tehsil Kumarsain, Distt. Shimla was inspected on 13-03-2017 with reference to his application no. Nil dated 08-03-2017 by the Leading Fireman, Fire Division Shimla-3 with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years (i.e.23-03-2017 to 22-03-2019) subject to fulfillment of the following conditions:-

1. You are advised to comply with the storage rule laid down by the Chief Controller of explosive with latest amendment, failing which this certificate shall be treated as cancelled.
2. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
3. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
4. Mock Drill shall be conducted in accordance with fire safety plan at least once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
Leela Indane Gramin Vitrak Pamlahi, Village Lower Pamlahi,  
P.O Thanedhar, Tehsil Kumarsain, Distt. Shimla H.P

TO WHOM IT MAY CONCERN

That the premises of Hotel King Palace Chhota Shimla-2, Distt. Shimla was inspected 20-01-2016 with reference to his application No. Nil dated 13-01-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 24-03-2017 to 23-03-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel King Palace Chhota Shimla-2 ,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of S.V.M Public School V.P.O Luhri, Tehsil Anni, Distt. Kullu was inspected on 08-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 03-04-2017 to 02-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.V.M Public School V.P.O Luhri,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Koshish Ek Asha Divyang School Rampur, Tehsil Rampur, Distt. Shimla was inspected on 10-01-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 03-04-2017 to 02-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Koshish Ek Asha Divyang School Rampur,  
Tehsil Rampur, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of S.D.A Mission Public School V.P.O Anni, Tehsil Anni, Distt. Kullu was inspected on 23-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 03-04-2017 to 02-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.D.A Mission Public School V.P.O Anni,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of The Twin Towers Hotel New Kufri Gallu, P.O Fagu, Distt. Shimla was inspected 05-04-2017 with reference to his application No. Nil dated 04-04-2017 by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 10-04-2017 to 09-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Proprietor,  
The Twin Towers Hotel New Kufri, Gallu,  
P.O Fagu, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Gables Promoters Pvt. Ltd. (Block A, C & D) Baldeyan, Distt. Shimla was inspected 29-03-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Training Center Baldeyan with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 11-04-2017 to 10-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel Gables Promoters Pvt. Ltd.  
(Block A, C & D) Baldeyan, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of New Daawat Corner, Sector-02, New Shimla, Distt. Shimla was inspected 30-03-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 12-04-2017 to 11-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Pankaj Arora,  
New Daawat Corner, Sector-02,  
New Shimla, Distt. Shimla H.P.



TO WHOM IT MAY CONCERN

That the premises of Rasal Sweet Shop Main Bazar Kasumpti, Shimla-9, Distt. Shimla was inspected 01-04-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Chhota Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Rasal Singh,  
Rasal Sweet Shop Main Bazar Kasumpti,  
Shimla-9, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hotel Grand White, Tutikandi, Below ISBT Shimla, Distt. Shimla was inspected 21-03-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
Sh. Dev Raj Verma,  
Hotel Grand White, Tutikandi,  
Below ISBT Shimla, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Kudos Laboratories India, Plot No. 12, Indl. Area Shoghi, Distt. Shimla was inspected 20-02-2017 with reference to his application No. Nil dated 17-01-2017 by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Kudos Laboratories India, Plot No. 12,  
Indl. Area Shoghi, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of University Institute of Information Technology, Building H.P.U Shimla-5, Distt. Shimla was inspected on 23-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Director,  
University Institute of Information Technology,  
Building H.P.U Shimla-5, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shaheed Bhagat Singh Memorial Public School Kufridhar, Ghanahatti, Distt. Shimla was inspected on 22-02-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shaheed Bhagat Singh Memorial Public School Kufridhar,  
Ghanahatti, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shivalik Public School Village Shegni, P.O Durah, Sub Tehsil Nithar, Distt. Kullu was inspected on 08-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shivalik Public School Village Shegni, P.O Durah,  
Sub Tehsil Nithar, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of S.V.M Public School Thanog, P.O Dalash, Tehsil Anni, Distt. Kullu was inspected on 08-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.V.M Public School Thanog, P.O Dalash,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Divya Lok Public School Haripur (Nigan), P.O & Tehsil Anni, Distt. Kullu was inspected on 23-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 18-04-2017 to 17-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Divya Lok Public School Haripur (Nigan),  
P.O & Tehsil Anni, Distt. Kullu H.P.



TO WHOM IT MAY CONCERN

That the premises of Hotel Harsha, The Mall, Shimla-4, Distt. Shimla was inspected 21-03-2017 with reference to his application No. Nil dated 14-03-2017 by the Incharge, Fire Station Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 19-04-2017 to 18-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Hotel Harsha, The Mall, Shimla-4,  
Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of New Vision Public School Dherikupur, Sub-Tehsil Tikker, Distt. Shimla was inspected on 10-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
New Vision Public School Dherikupur,  
Sub-Tehsil Tikker, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of S.D.A Mission High School Housing Colony Samalah, Tehsil Rohru, Distt. Shimla was inspected on 10-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
S.D.A Mission High School Housing Colony Samalah,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Chander Nahan High School Rahru, Tehsil Rohru, Distt. Shimla was inspected on 29-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Chander Nahan High School Rahru,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Lord Krishna Public Primary School Kuthari, Tehsil Rohru, Distt. Shimla was inspected on 11-04-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Lord Krishna Public Primary School Kuthari,  
Tehsil Rohru, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Ashadeep Public Middle School Badiyar, Tehsil Chirgaon, Distt. Shimla was inspected on 12-04-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Ashadeep Public Middle School Badiyar,  
Tehsil Chirgaon, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Shivalik Public School V.P.O Dalash, Tehsil Anni, Distt. Kullu was inspected on 20-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Shivalik Public School V.P.O Dalash,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Adarsh Public School V.P.O Khun, Tehsil Anni, Distt. Kullu was inspected on 20-03-2017 with reference to application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 27-04-2017 to 26-04-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Adarsh Public School V.P.O Khun,  
Tehsil Anni, Distt. Kullu H.P.



TO WHOM IT MAY CONCERN

That the premises of Govt. High School Annadale, Shimla-3, Distt. Shimla was inspected on 06-05-2017 with reference to application No. Nil dated Nil by the Divisional Fire Officer, Fire Division Shimla-3 with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years(i.e. 08-05-2017 to 07-05-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Headmaster,  
Govt. High School Annadale,  
Shimla-3, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of Hill Top Public School V.P.O Khanag,  
Tehsil Anni, Distt. Kullu was inspected on 15-04-2017 with reference to application No.  
Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for  
protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant  
at his premises were found satisfactory at the time of inspection. Hence, No Objection  
Certificate is issued/ renewed for Two years(i.e. 11-05-2017 to 10-05-2019) subject to  
fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to  
handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the  
fire fighting equipment/ system in perfect running condition, failing which this  
certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in  
every three months and written record shall be kept in the premises for the  
inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local  
Fire Officer during annual day function or any other function in the school  
where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Hill Top Public School V.P.O Khanag,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Hill Top Public School V.P.O Khanag,  
Tehsil Anni, Distt. Kullu was inspected on 15-04-2017 with reference to application No.  
Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for  
protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant  
at his premises were found satisfactory at the time of inspection. Hence, No Objection  
Certificate is issued/ renewed for Two years(i.e. 11-05-2017 to 10-05-2019) subject to  
fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to  
handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the  
fire fighting equipment/ system in perfect running condition, failing which this  
certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in  
every three months and written record shall be kept in the premises for the  
inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local  
Fire Officer during annual day function or any other function in the school  
where temporary structures and Pandals are to be erected.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Hill Top Public School V.P.O Khanag,  
Tehsil Anni, Distt. Kullu H.P.

TO WHOM IT MAY CONCERN

That the premises of Kurmi Energy (P) Ltd. V.P.O Phancha, Tehsil Rampur, Distt. Shimla was inspected 13-04-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Rampur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 11-05-2017 to 10-05-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
Kurmi Energy (P) Ltd. V.P.O Phancha,  
Tehsil Rampur, Distt. Shimla H.P.

TO WHOM IT MAY CONCERN

That the premises of N.S.L Masli Power Generation Pvt. Ltd. Tehsil Chirgaon, Distt. Shimla was inspected 12-04-2017 with reference to his application No. Nil dated Nil by the Incharge, Fire Station Rohru with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for Two years (i.e 11-05-2017 to 10-05-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Good House keeping must be maintained with in the premises.

Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Manager,  
N.S.L Masli Power Generation Pvt. Ltd.  
Tehsil Chirgaon, Distt. Shimla H.P.